

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0495-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAG10CP010
Instrument Description CONDENSER VACUUM 2
Manufacture YOKOGAWA
Model / Serial Number EJX110A / 91V703041
Instrument Location TURBINE 3RD FLOOR

Range -1000 ~ 1000
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 06-06-2026

Environment Condition

Temperature 32 °C Humidity 74 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-926.000	4.592	4.645	0.053	0.331	Pass						
-449.900	8.001	8.053	0.052	0.325	Pass						
0.000	12.000	12.053	0.053	0.331	Pass						
499.900	16.000	16.054	0.054	0.338	Pass						
999.700	20.000	20.056	0.056	0.350	Pass						
499.900	16.000	16.056	0.056	0.350	Pass						
0.000	12.000	12.053	0.053	0.331	Pass						
-499.900	8.001	8.053	0.052	0.325	Pass						
-926.000	4.592	4.644	0.052	0.325	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD6	6094437	02170/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 10-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Ivan Hasanudin

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person