

## CERTIFICATE OF CALIBRATION

### DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0397-24-HI-CAL-10C

#### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

#### Instrument Information

KKS No.	60MAG10CP015	Range	-1000 ~ 1000
Instrument Description	CONDENSER VACUUM 3	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V703042	Cal. Date	10-05-2024
Instrument Location	TURBINE 3RD FLOOR		

#### Environment Condition

Temperature 28 °C  
Humidity 52 % RH

#### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-1000	4.610	4.652	0.042	0.262	Pass						
-500	8.000	8.043	0.043	0.269	Pass						
0	12.000	12.044	0.044	0.275	Pass						
500	16.000	16.041	0.041	0.256	Pass						
1000	20.000	20.037	0.037	0.231	Pass						
1000	20.000	20.037	0.037	0.231	Pass						
500	16.000	16.042	0.042	0.263	Pass						
0	12.000	12.041	0.041	0.256	Pass						
-500	8.000	8.042	0.042	0.262	Pass						
-1000	4.600	4.643	0.043	0.269	Pass						

#### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

#### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page

Date of issue, 11-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved By,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

