

## CERTIFICATE OF CALIBRATION

### DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0398-24-HI-CAL-10C

#### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

#### Instrument Information

KKS No. 60MAG10CP020 Range -1000 ~ 1000  
Instrument Description CONDENSER VACUUM 4 Unit mbar  
Manufacture YOKOGAWA Out. Signal 4 - 20 mA  
Model EJX110A Max. Error 0.5 %  
Serial Number 91V703043 Cal. Date 10-05-2024  
Instrument Location TURBINE 3RD FLOOR

#### Environment Condition

Temperature 27.9 °C  
Humidity 51 % RH

#### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-1000	4.610	4.614	0.004	0.025	Pass						
-500	8.000	8.012	0.012	0.075	Pass						
0	12.000	12.020	0.020	0.125	Pass						
500	16.000	16.026	0.026	0.162	Pass						
1000	20.000	20.033	0.033	0.206	Pass						
1000	20.000	20.033	0.033	0.206	Pass						
500	16.000	16.026	0.026	0.162	Pass						
0	12.002	12.021	0.019	0.119	Pass						
-500	8.000	8.011	0.011	0.069	Pass						
-1000	4.578	4.583	0.005	0.031	Pass						

#### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

#### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 11-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Faisnol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

