

CERTIFICATE OF CALIBRATION LEVEL SWITCH

Certificate No. : 0175-24-HI-CAL-101

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60MAG15CL305 Type of Testing Function Test
Instrument Description CONDENSER WATER BOX A LEVEL HIGH Cal. Date 29-05-2024
Manufacture -
Model -
Serial Number -
Instrument Location TURBINE 1ST FLOOR

Environment Condition

Temperature 33 °C
Humidity 43 % RH

Calibration Result

Data Reading (Switch)			
As Found		As Left	
Switch	Result	Switch	Result
Set (NC)	OK		
Reset (NO)	OK		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022

Calibration Method

004 / Service-HI / 2019
Standard Operating Procedure of Level Switch Calibration

This certificate comprise of 1 page
Date of issue, 30-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,

HERVITAMA



M. Nur Nugra Ariyan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

