

CERTIFICATE OF CALIBRATION
LEVEL SWITCH

Certificate No. : 1093-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAG15CL305
Instrument Description CONDENSER WATER BOX A LEVEL HIGH
Manufacture NAKAKITA SEISAKUSHO
Model / Serial Number NS287-71 / -
Instrument Location TURBINE 1ST FLOOR

Type of Testing Function Test
Cal. Date 09-06-2026

Environment Condition

Temperature 28 °C Humidity 61 % RH

Calibration Result

Data Reading (Switch)			
As Found		As Left	
Open to Close	Close to Open	Open to Close	Close to Open
OK	OK		
OK	OK		
OK	OK		

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
TRUE RMS Multimeter Fluke 87V	45910296	UAL/04843/26	23-04-2026

Calibration Method

0004/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Switch

This certificate comprises 2 pages
Date of issue, 14-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

Wati Nisrah Asnari

Calibrated by,

M. Taufiq Nur Fitriyan

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person