

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0399-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAN51CF001	Range	0 ~ 2.5
Instrument Description	HIGH PRESSURE TURBINE BYPASS SPRAY WATER FLOW	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX411A	Max. Error	0.5 %
Serial Number	91V501684	Cal. Date	28-05-2024
Instrument Location	TURBINE 1ST FLOOR		

Environment Condition

Temperature: 30 °C
Humidity: 77 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	3.999	-0.001	-0.006	Pass						
0.625	8.000	8.000	0.000	0.000	Pass						
1.250	12.000	11.997	-0.003	-0.019	Pass						
1.875	16.000	15.994	-0.006	-0.037	Pass						
2.500	20.000	19.993	-0.007	-0.044	Pass						
2.500	20.000	19.993	-0.007	-0.044	Pass						
1.875	16.000	15.990	-0.010	-0.063	Pass						
1.250	12.000	11.996	-0.004	-0.025	Pass						
0.625	8.000	7.996	-0.004	-0.025	Pass						
0.000	4.000	3.997	-0.003	-0.019	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter


This certificate comprise of 1 page
Date of issue, 29-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

