

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0498-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAN51CF001
Instrument Description HIGH PRESSURE TURBINE BYPASS SPRAY WATER FLOW
Manufacture YOKOGAWA
Model / Serial Number EJX411A / 91V501684
Instrument Location TURBINE 1ST FLOOR

Range 0 ~ 2500
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 04-06-2026

Environment Condition

Temperature 31 °C Humidity 73 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	4.002	0.002	0.013	Pass						
624.700	8.000	7.997	-0.003	-0.019	Pass						
1250.000	12.000	11.997	-0.003	-0.019	Pass						
1875.400	16.000	15.995	-0.005	-0.031	Pass						
2500.000	20.000	19.990	-0.010	-0.063	Pass						
1878.400	16.000	15.993	-0.007	-0.044	Pass						
1250.000	12.000	11.995	-0.005	-0.031	Pass						
624.700	8.000	7.996	-0.004	-0.025	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD6	6094437	02170/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 08-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Authorized Signatory,

HERVITAMA INDONESIA

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person