

CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0518-24-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

| | | | |
|------------------------|--|-----------|------------|
| KKS No. | 60MAV10CP305 | Range | 1 - 10 |
| Instrument Description | LUBE OIL PRESSURE LOW (EMERGENCY OIL PUMP START) | Set | 2.82 |
| Manufacture | NAGANO KEIKI | Reset | 3.13 |
| Model | CB33 | Unit | bar |
| Serial Number | W12313 | MPE | ± 0.045 |
| Instrument Location | TURBINE 2ND FLOOR | Cal. Date | 15-05-2024 |

Environment Condition

Temperature 30.7 °C
 Humidity 59 % RH

Calibration Result

| Data Reading (Switch) | | | | | |
|-----------------------|-------|----------|---------|-------|----------|
| As Found | | | As Left | | |
| Set | Reset | Deadband | Set | Reset | Deadband |
| 2.831 | 3.145 | 0.314 | 2.816 | 3.134 | 0.318 |
| 2.831 | 3.145 | 0.314 | 2.817 | 3.135 | 0.318 |
| 2.831 | 3.145 | 0.314 | 2.817 | 3.135 | 0.318 |

Standard Reference

| Description | Serial Number | Certificate Number | Calibration Date |
|--|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 3611011 | S. 22 011 747 | 23-09-2023 |
| Fluke Pressure Module 750PD27 | 6087359 | S. 23 014 459 | 09-10-2023 |

Calibration Method

0003/SOP_BJS/2023
 Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
 Date of issue, 16-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. INDONESIA INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

