

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0687-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAV15CT005	Range	0 ~ 100
Instrument Description	MAIN OIL COOLER OUTLET OIL TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	1.7 °C (JIS)
Serial Number	5346975	Cal. Date	18-05-2024
Instrument Location	TURBINE 2ND FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 28.8 °C
Humidity 59 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.020	39.900	-0.120	Pass					
45	45.000	45.100	0.100	Pass					
50	50.000	50.200	0.200	Pass					
75	75.010	75.600	0.590	Pass					
100	100.130	100.700	0.570	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 19-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Tahir Nur Ariyan

Calibrated by,



Khajib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

