

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0961-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAV15CT005 Range 0 ~ 100
Instrument Description MAIN OIL COOLER OUTLET OIL TEMPERATURE Unit °C
Manufacture YAMARI Out. Signal 4 - 20 mA
Model / Serial Number - / 5346975 Max. Deviation 1.7 °C (JIS)
Instrument Location TURBINE 2ND FLOOR Cal. Date 29-05-2026
Temp. Element Thermocouple Type E

Environment Condition

Temperature 25.9 °C Humidity 71 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	39.900	0.300	Pass					
45	44.600	44.700	0.100	Pass					
50	49.500	50.100	0.600	Pass					
75	74.970	75.000	0.030	Pass					
100	99.920	100.700	0.780	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS	3611011	MAL 26031229	06-03-2026
CALIBRATOR FLUKE 754			
DRY WELL CALIBRATOR ADDITEL	660TH19040016	S-25010822	22-08-2025
875			

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 31-05-2026

Customer Signature,

Ayrtan Humardani Putradhi

HERVITAMA,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person