

CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0520-24-HI-CAL-10B

Customer Information

Company Name PT. Bumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAV52CP305	Range	0.6 - 6
Instrument Description	TURNING GEAR INTERLOCK PRESSURE HIGH	Set	1.79
Manufacture	NAGANO KEIKI	Reset	1.60
Model	CB33	Unit	barg
Serial Number	W12882	MPE	± 0.027
Instrument Location	TURBINE 2ND FLOOR	Cal. Date	15-05-2024

Environment Condition

Temperature 30.7 °C
 Humidity 59 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
1.804	1.624	0.180	1.794	1.611	0.183
1.804	1.621	0.183	1.794	1.613	0.181
1.804	1.621	0.183	1.794	1.613	0.181

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0003/SOP_BJS/2023
 Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
 Date of issue, 16-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. INDONESIA an

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person