

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0401-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60MAV60CP005	Range	0.692 ~ 10.692
Instrument Description	TURBINE LUBE OIL PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703395	Cal. Date	15-05-2024
Instrument Location	TURBINE 2ND FLOOR		

### Environment Condition

Temperature: 30.7 °C  
 Humidity: 59 % RH

### Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.692	4.000	3.984	-0.016	-0.100	Pass						
3.192	8.000	7.987	-0.013	-0.081	Pass						
5.692	12.000	11.992	-0.008	-0.050	Pass						
8.192	16.000	15.990	-0.010	-0.062	Pass						
10.692	20.000	19.992	-0.008	-0.050	Pass						
10.692	20.000	19.992	-0.008	-0.050	Pass						
8.192	16.000	16.000	0.000	0.000	Pass						
5.692	12.000	11.996	-0.004	-0.025	Pass						
3.192	8.000	7.996	-0.004	-0.025	Pass						
0.692	4.000	3.994	-0.006	-0.037	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 16-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fauzan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

