

## CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0521-24-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60MAV60CP305  
 Instrument Description TURBINE LUBE OIL PRESSURE LOW LOW 3  
 Manufacture NAGANO KEIKI  
 Model CB33  
 Serial Number W12881  
 Instrument Location TURBINE 2ND FLOOR

Range 0.6 - 6  
 Set 1.380  
 Reset 1.750  
 Unit barg  
 MPE ± 0.027  
 Cal. Date 15-05-2024

### Environment Condition

Temperature 30.7 °C  
 Humidity 59 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
1.404	1.777	0.373	1.382	1.753	0.371
1.404	1.780	0.376	1.382	1.754	0.372
1.404	1.780	0.376	1.382	1.754	0.372

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

### Calibration Method

0003/SOP\_BJS/2023  
 Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
 Date of issue, 16-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Indonesia Yan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person