

CERTIFICATE OF CALIBRATION  
PRESSURE SWITCH

Certificate No. : 0056-26-HI-CAL-10

## Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

KKS No. 60LAV31CP305  
Instrument Description BFPT A LUBE OIL PRESSURE LOW 1  
Manufacture NAGANO KEIKI  
Model / Serial Number CB33 / W12109  
Instrument Location TURBINE 1ST FLOOR

Range 0.2 - 2  
Set 0.281  
Reset 0.486  
Unit bar g  
MPE  $\pm 0.009$   
Cal. Date 02-06-2026

## Environment Condition

Temperature 31 °C Humidity 72 % RH

## Calibration Result

| Data Reading (Switch) |       |          |         |       |          |
|-----------------------|-------|----------|---------|-------|----------|
| As Found              |       |          | As Left |       |          |
| Set                   | Reset | Deadband | Set     | Reset | Deadband |
| 0.278                 | 0.476 | 0.198    |         |       |          |
| 0.276                 | 0.477 | 0.201    |         |       |          |
| 0.278                 | 0.476 | 0.198    |         |       |          |

## Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

## Standard Reference

| Description                                 | Serial Number | Certificate Number   | Calibration Date |
|---------------------------------------------|---------------|----------------------|------------------|
| DOCUMENTING PROCESS<br>CALIBRATOR FLUKE 754 | 2448033       | 4482/25/EX/10/2025   | 26-09-2025       |
| FLUKE PRESURE MODULE 750PD6                 | 6094437       | 02170/GQI-Sert/03/26 | 09-03-2026       |

## Calibration Method

0003/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure Switch

This certificate comprises 2 pages  
Date of issue, 06-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

HERVITAMA  
  
INDONESIA

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person