

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0963-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60MAW18CT005

Instrument Description

GLAND STEAM TEMPERATURE

Manufacture

YAMARI

Model / Serial Number

-/-

Instrument Location

Turbine 1st Floor

Range

0 ~ 500

Unit

°C

Out. Signal

4-20 mA

Max. Deviation

5 °C

Cal. Date

23-06-2026

Temp. Element

Thermocouple Type E

Environment Condition

Temperature

30,1 °C

Humidity

53 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	40.000	0.400	Pass					
125	125.800	125.300	-0.500	Pass					
250	251.700	250.600	-1.100	Pass					
375	376.900	375.900	-1.000	Pass					
500	502.300	501.100	-1.200	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

DRY WELL CALIBRATOR ADDITEL

660TH19040016

S-25010822

22-08-2025

875

Temperature Calibrator Fluke 725

2815000

2256/25/KAL/06/2025

23-06-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 24-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

HERVITAMA
INDONESIA

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

