

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0511-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAW61CP001
Instrument Description BFPT A GLAND STEAM PRESSURE
Manufacture YOKOGAWA
Model / Serial Number EJX130A / 91V7033999277
Instrument Location TURBINE 1ST FLOOR

Range -917 ~ 2083
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 03-06-2026

Environment Condition

Temperature 31 °C Humidity 72 % RH

Calibration Result

As Found						Data Reading (Transmitter)						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-917.000	4.000	4.000	0.000	0.000	Pass												
-166.900	8.000	7.997	-0.003	-0.019	Pass												
583.300	12.000	11.997	-0.003	-0.019	Pass												
1333.400	16.000	15.997	-0.003	-0.019	Pass												
2082.900	20.000	19.998	-0.002	-0.013	Pass												
1333.400	16.000	15.996	-0.004	-0.025	Pass												
583.300	12.000	11.997	-0.003	-0.019	Pass												
-166.900	8.000	7.998	-0.002	-0.013	Pass												
-917.000	4.000	4.000	0.000	0.000	Pass												

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 700P05	14270508	02837/GQI-Sert/04/26	13-04-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 07-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,
HERVITAMA

INDONESIA

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

