

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0512-26-HI-CAL-10

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

### Instrument Information

|                        |                             |             |             |
|------------------------|-----------------------------|-------------|-------------|
| KKS No.                | 60MAW62CP001                | Range       | -889 ~ 2111 |
| Instrument Description | BFPT B GLAND STEAM PRESSURE | Unit        | mbar        |
| Manufacture            | YOKOGAWA                    | Out. Signal | 4 - 20 mA   |
| Model / Serial Number  | EJX430A / 91V7034009277     | Max. Error  | 0.5 %       |
| Instrument Location    | TURBINE 1ST FLOOR           | Cal. Date   | 03-06-2026  |

### Environment Condition

Temperature 31 °C Humidity 73 % RH

### Calibration Result

| Data Reading (Transmitter) |            |            |           |        |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |        |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [mbar]                     | [mA]       | [mA]       |           | [%]    |        | [mbar]  | [mA]       | [mA]       |           | [%]   |        |
| -889.000                   | 4.000      | 3.998      | -0.002    | -0.013 | Pass   |         |            |            |           |       |        |
| -139.000                   | 8.000      | 7.999      | -0.001    | -0.006 | Pass   |         |            |            |           |       |        |
| 611.000                    | 12.000     | 11.995     | -0.005    | -0.031 | Pass   |         |            |            |           |       |        |
| 1361.000                   | 16.000     | 15.998     | -0.002    | -0.013 | Pass   |         |            |            |           |       |        |
| 2111.000                   | 20.000     | 19.998     | -0.002    | -0.013 | Pass   |         |            |            |           |       |        |
| 1361.000                   | 16.000     | 15.997     | -0.003    | -0.019 | Pass   |         |            |            |           |       |        |
| 611.000                    | 12.000     | 11.998     | -0.002    | -0.013 | Pass   |         |            |            |           |       |        |
| -139.000                   | 8.000      | 7.996      | -0.004    | -0.025 | Pass   |         |            |            |           |       |        |
| -889.000                   | 4.000      | 3.999      | -0.001    | -0.006 | Pass   |         |            |            |           |       |        |

### Visual Inspection (Checklist if OK)

|                   |                                     |                 |                                     |                 |                                     |
|-------------------|-------------------------------------|-----------------|-------------------------------------|-----------------|-------------------------------------|
| Leak Check        | <input checked="" type="checkbox"/> | Tightness Check | <input checked="" type="checkbox"/> | Corrosion Check | <input checked="" type="checkbox"/> |
| Accessories Check | <input checked="" type="checkbox"/> | Power Supply    | <input checked="" type="checkbox"/> |                 |                                     |

### Standard Reference

| Description                              | Serial Number | Certificate Number  | Calibration Date |
|------------------------------------------|---------------|---------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 2448033       | 4482/25/EX/10/2025  | 26-09-2025       |
| FLUKE PRESURE MODULE 700P05              | 14270508      | 02837/GQI-Ser/04/26 | 13-04-2026       |

### Calibration Method

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 07-06-2026

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA

INDONESIA  
Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person