

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0405-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAX30CP001	Range	0 - 250
Instrument Description	EHC OIL PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX440A	Max. Error	0.5 %
Serial Number	91V729775	Cal. Date	14-05-2024
Instrument Location	TURBINE 1ST FLOOR		

Environment Condition

Temperature: 29.9 °C
Humidity: 64 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	3.987	-0.013	-0.081	Pass						
62.54	8.000	7.987	-0.013	-0.081	Pass						
125.00	12.000	11.990	-0.010	-0.063	Pass						
187.54	16.000	15.997	-0.003	-0.019	Pass						
250.00	20.000	19.997	-0.003	-0.019	Pass						
187.54	16.000	15.993	-0.007	-0.044	Pass						
125.00	12.000	11.990	-0.010	-0.063	Pass						
62.54	8.000	7.992	-0.008	-0.050	Pass						
0.00	4.000	3.985	-0.015	-0.094	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 15-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

