

## CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0526-24-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60MAX30CP304	Range	15 - 150
Instrument Description	EHC OIL PRESSURE LOW LOW 3	Set	114
Manufacture	NAGANO KEIKI	Reset	120
Model	CB33	Unit	barg
Serial Number	W11754	MPE	± 0.675
Instrument Location	TURBINE 1ST FLOOR	Cal. Date	14-05-2024

### Environment Condition

Temperature 29.9 °C  
Humidity 64 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
113.070	118.450	5.380	114.180	119.690	5.510
113.070	118.450	5.380	114.180	119.690	5.510
113.070	118.450	5.380	114.180	119.690	5.510

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 15-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

