

**CERTIFICATE OF CALIBRATION**  
**DIFFERENTIAL PRESSURE TRANSMITTER**

Certificate No. : 0406-24-HI-CAL-10C

**Customer Information**

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

**Instrument Information**

KKS No.	60MKF50CF001	Range	0 ~ 250
Instrument Description	STATOR COOLING WATER GENERATOR INLET FLOW	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX411A	Max. Error	0.5 %
Serial Number	91V412322	Cal. Date	28-05-2024
Instrument Location	TURBINE 1ST FLOOR		

**Environment Condition**

Temperature: 30 °C  
Humidity: 77 % RH

**Calibration Result**

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	4.001	0.001	0.006	Pass						
62.5	8.000	8.003	0.003	0.019	Pass						
125.0	12.000	11.993	-0.007	-0.044	Pass						
187.5	16.000	16.000	0.000	0.000	Pass						
250.0	20.000	20.003	0.003	0.019	Pass						
250.0	20.000	20.003	0.003	0.019	Pass						
187.5	16.000	16.005	0.005	0.031	Pass						
125.0	12.000	12.000	0.000	0.000	Pass						
62.5	8.000	8.005	0.005	0.031	Pass						
0.0	4.000	4.002	0.002	0.013	Pass						

**Standard Reference**

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

**Calibration Method**

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 29-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

