

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0407-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MKF50CP001	Range	0.97 ~ 10.97
Instrument Description	STATOR COOLING WATER GENERATOR INLET PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V412323	Cal. Date	14-05-2024
Instrument Location	TURBINE 1ST FLOOR		

Environment Condition

Temperature: 30.1 °C
Humidity: 63 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.97	4.000	3.977	-0.023	-0.144	Pass						
3.47	8.000	7.975	-0.025	-0.156	Pass						
5.97	12.000	11.974	-0.026	-0.163	Pass						
8.47	16.000	15.979	-0.021	-0.131	Pass						
10.97	20.000	19.977	-0.023	-0.144	Pass						
10.97	20.000	19.977	-0.023	-0.144	Pass						
8.47	16.000	15.989	-0.011	-0.069	Pass						
5.97	12.000	11.981	-0.019	-0.119	Pass						
3.47	8.000	7.982	-0.018	-0.112	Pass						
0.97	4.000	3.981	-0.019	-0.119	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 15-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

