

CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0529-24-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MKF50CP303	Range	0.4 - 4
Instrument Description	STATOR COOLING WATER GENERATOR INLET PRESSURE LOW LOW 1	Set	2.690
Manufacture	NAGANO KEIKI	Reset	2.810
Model	CB33	Unit	barg
Serial Number	W12715	MPE	± 0.018
Instrument Location	TURBINE 1ST FLOOR	Cal. Date	14-05-2024

Environment Condition

Temperature 30.1 °C
 Humidity 63 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
2.609	2.727	0.118	2.698	2.819	0.121
2.600	2.721	0.121	2.692	2.816	0.124
2.600	2.721	0.121	2.692	2.816	0.124

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0003/SOP_BJS/2023
 Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
 Date of issue, 15-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Firman

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

