# REPORT OF INSPECTION
# MOTORIZED OF VALVE

Certificate No. : 0951-24-HI-CAL-10J

**Customer Information**

| | |
|---|---|
| Company Name | PT. Bhumi Jati Power |
| Address | PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah |
| Contract No. | C-BJP-24-0014-OTH |

**Instrument Information**

| | | | |
|---|---|---|---|
| KKS No. | 60PAB10AA205 | Power Supply | 380 VAC |
| Instrument Description | CONDR WTRBOX A INLET VALVE | Stroke | 45 deg |
| Manufacture | AUMA | | |
| Model | SA14-6-F14 | Inspection Date | 27-05-2024 |
| Serial Number | 0219MD85945 | | |
| Instrument Location | TURBINE UNDERGROUND | | |

**Environment Condition**

| | |
|---|---|
| Temperature | 31 °C |
| Humidity | 44 % RH |

**Traveling Time**

| | |
|---|---|
| Open to Close | 94.78 s |
| Close to Open | 94.31 s |

**Stroke Result**

| Command | Local | Stroke | DCS FB |
|---|---|---|---|
| [%] | [%] | [deg] | [%] |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| Command | Feadback | | | |
|---|---|---|---|---|
| | Local | | DCS | |
| | Open | Close | Open | Close |
| Close | - | OK | - | OK |
| Open | OK | - | OK | - |

**Visual Inspection**

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| Leak Check | ✓ | OK | | Not OK | Tighteness Check | ✓ | OK | | Not OK |
| Corrosion Condition | ✓ | OK | | Not OK | Accessories Check | ✓ | OK | | Not OK |
| Gearbox Condition | ✓ | OK | | Not OK | | | | | |

**Remark**

**Test Equipment**

| Description | Serial Number | Certificate Number | Calibration Date |
|---|---|---|---|
| Digital Multimeter Fluke 87V | 16230349 | S. 22 008 274 | 08-07-2022 |
| STOPWATCH CASIO | J011Q03 | S. 23 004 599 | 27-03-2023 |

**Inspection Method**

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 28-05-2024

| Customer Signature, | Approved Signatory, | Calibrated by, |
|---|---|---|
| Ayrton Humardani Putradhi | M. Taufiq Nur Fikriyan | Suryo Wicaksono |

HERVITAMA INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*
*This certificate is valid if it has approved and signed by authorized person*