

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0409-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60PAB15CP005	Range	-1.014 ~ 4.986
Instrument Description	CONDENSER WATER BOX A OUTLET PRESSURE	Unit	bar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX438A	Max. Error	0.5 %
Serial Number	91X305159	Cal. Date	13-05-2024
Instrument Location	TURBINE UNDER GROUND		

Environment Condition

Temperature 30.9 °C
Humidity 63 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]	
-0.800	4.570	4.568	-0.002	-0.013	Pass						
0.486	8.000	7.960	-0.040	-0.250	Pass						
1.986	12.000	11.968	-0.032	-0.200	Pass						
3.486	16.000	15.971	-0.029	-0.181	Pass						
4.986	20.000	19.971	-0.029	-0.181	Pass						
4.986	20.000	19.971	-0.029	-0.181	Pass						
3.486	16.000	15.968	-0.032	-0.200	Pass						
1.986	12.000	11.968	-0.032	-0.200	Pass						
0.486	8.000	7.959	-0.041	-0.256	Pass						
-0.800	4.570	4.579	0.009	0.056	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 14-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

This certificate is valid if it has approved and signed by authorized person