

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0410-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60PAB16CP005	Range	-1.014 ~ 4.986
Instrument Description	CONDENSER WATER BOX B OUTLET PRESSURE	Unit	bar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX438A	Max. Error	0.5 %
Serial Number	91X305160	Cal. Date	13-05-2024
Instrument Location	TURBINE UNDER GROUND		

Environment Condition

Temperature: 30.9 °C
Humidity: 63 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]	
-0.800	4.570	4.550	-0.020	-0.125	Pass						
0.486	8.000	7.948	-0.052	-0.325	Pass						
1.986	12.000	11.960	-0.040	-0.250	Pass						
3.486	16.000	15.958	-0.042	-0.262	Pass						
4.986	20.000	19.968	-0.032	-0.200	Pass						
4.986	20.000	19.968	-0.032	-0.200	Pass						
3.486	16.000	15.960	-0.040	-0.250	Pass						
1.986	12.000	11.964	-0.036	-0.225	Pass						
0.486	8.000	7.965	-0.035	-0.219	Pass						
-0.800	4.570	4.572	0.002	0.012	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 14-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fityan
INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

