

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0526-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60PAB16CP005 Range -1.014 ~ 4.986
Instrument Description CONDENSER WATER BOX B OUTLET PRESSURE Unit bar g
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX438A / 91X305160 Max. Error 0.5 %
Instrument Location TURBINE UNDER GROUND Cal. Date 15-06-2026

Environment Condition

Temperature 31.8 °C Humidity 58 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
-0.800	4.570	4.584	0.014	0.088	Pass						
0.486	8.000	8.020	0.020	0.125	Pass						
1.986	12.000	12.018	0.018	0.113	Pass						
3.486	16.000	16.036	0.036	0.225	Pass						
4.986	20.000	20.025	0.025	0.156	Pass						
3.486	16.000	16.026	0.026	0.163	Pass						
1.986	12.000	12.018	0.018	0.113	Pass						
0.485	7.997	8.020	0.023	0.144	Pass						
-0.800	4.570	4.564	-0.006	-0.038	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
PRESSURE MODULE FLK 750PD27	6087359	02172/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 16-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Authorized Signatory,

Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person