

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0692-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60PAB16CT005	Range	0 ~ 80
Instrument Description	CONDENSER TUBE BALL STRAINER B OUTLET WATER TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	1.7 °C (JIS)
Serial Number	5392900	Cal. Date	18-05-2024
Instrument Location	TURBINE UNDER GROUND	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 28.9 °C
Humidity 51 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.020	40.100	0.080	Pass					
50	50.010	50.200	0.190	Pass					
60	60.010	60.300	0.290	Pass					
70	70.000	70.500	0.500	Pass					
80	80.000	80.700	0.700	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 060	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 19-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



INDONESIA
M. Taufiq Nur Fitriyan

Calibrated by,



Khahib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

