

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0531-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60PAH11CP005
Instrument Description CONDENSER TUBE BALL STRAINER A DIFFERENTIAL PRESSURE TRANSMITTER
Manufacture ROSEMOUNT
Model / Serial Number 3051CD2A22A1AS2M5B4D4Q4 / 8648782
Instrument Location TURBINE UNDERGROUND

Range 0 ~ 200
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 15-06-2026

Environment Condition

Temperature 31.8 °C Humidity 58 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	4.000	0.000	0.000	Pass						
50.000	8.000	8.014	0.014	0.088	Pass						
100.000	12.000	11.981	-0.019	-0.119	Pass						
150.000	16.000	15.953	-0.047	-0.294	Pass						
199.900	19.992	19.956	-0.036	-0.225	Pass						
150.000	16.000	15.956	-0.044	-0.275	Pass						
100.000	12.000	11.984	-0.016	-0.100	Pass						
50.000	8.000	8.019	0.019	0.119	Pass						
0.000	4.000	4.043	0.043	0.269	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 16-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

HERVITAMA,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person