

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0536-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60PGA04CP005	Range	0.254 ~ 15.254
Instrument Description	CLOSEDCYCLE COOLING WATER HEAT EXCHANGER INLETCLOSEDCYCLE COOLING WATER PRESSURE	Unit	bar g
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model / Serial Number	EJX430A / 91V703401	Max. Error	0.5 %
Instrument Location	TURBINE 1ST FLOOR	Cal. Date	29-05-2026

Environment Condition

Temperature 30.8 °C Humidity 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
0.254	4.000	3.998	-0.002	-0.013	Pass						
4.004	8.000	7.998	-0.002	-0.013	Pass						
7.754	12.000	11.998	-0.002	-0.013	Pass						
11.505	16.001	15.998	-0.003	-0.019	Pass						
15.254	20.000	19.998	-0.002	-0.013	Pass						
11.504	16.000	16.000	0.000	0.000	Pass						
7.754	12.000	11.999	-0.001	-0.006	Pass						
4.004	8.000	8.000	0.000	0.000	Pass						
0.254	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check	☒	Tightness Check	☒	Corrosion Check	☒
Accessories Check	☒	Power Supply	☒		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
PRESSURE MODULE FLK 750PD27	6087359	02172/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 03-06-2026

Customer Signature,



Ayrtan Humardani Putradhi

Authorized Signatory,



Ivan Hasan Ashari

Calibrated by,



Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

