

## CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0092-26-HI-CAL-10

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-26-0004-OTH

### Instrument Information

KKS No. 60QFB01CP305  
 Instrument Description DEARATOR AND FEED WATER TANK LEVEL CONTROL VALVE PRESSURE LOW  
 Manufacture NAGANO KEIKI  
 Model / Serial Number - / -  
 Instrument Location TURBINE 1ST FLOOR

Range 1 - 10  
 Set 4.500  
 Reset 4.809  
 Unit bar g  
 MPE  $\pm 0.045$   
 Cal. Date 28-05-2026

### Environment Condition

Temperature 31 °C Humidity 65 % RH

### Calibration Result

| Data Reading (Switch) |       |          |         |       |          |
|-----------------------|-------|----------|---------|-------|----------|
| As Found              |       |          | As Left |       |          |
| Set                   | Reset | Deadband | Set     | Reset | Deadband |
| 4.998                 | 5.205 | 0.207    | 4.507   | 4.778 | 0.271    |
| 4.998                 | 5.205 | 0.207    | 4.507   | 4.778 | 0.271    |
| 4.998                 | 5.205 | 0.207    | 4.507   | 4.778 | 0.271    |

### Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
 Accessories Check ☒ Power Supply ☒

### Standard Reference

| Description                                 | Serial Number | Certificate Number   | Calibration Date |
|---------------------------------------------|---------------|----------------------|------------------|
| DOCUMENTING PROCESS<br>CALIBRATOR FLUKE 754 | 56070038      | MAL 26031230         | 06-03-2026       |
| PRESSURE MODULE FLK 750PD27                 | 6087359       | 02172/GQI-Sert/03/26 | 09-03-2026       |

### Calibration Method

0003/SOP\_BJS/2025  
 Standard Operating Procedure of Calibration Pressure Switch

This certificate comprises 2 pages  
 Date of issue, 03-06-2026

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



INDONESIA  
 Ivan Hasan Ashari

Calibrated by,



Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person