

CERTIFICATE OF CALIBRATION
PRESSURE SWITCH

Certificate No. : 0099-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60QFB01CP340
Instrument Description AUX STEAM SEAL FEED CONTROL VALVE PRESSURE LOW
Manufacture NAGANO KEIKO
Model / Serial Number - / W12878
Instrument Location TURBINE 2ND FLOOR

Range 1 - 10
Set 2.7
Reset 2.962
Unit bar
MPE ± 0.045
Cal. Date 06-06-2026

Environment Condition

Temperature 31 °C Humidity 74 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
2.693	2.866	0.173			
2.693	2.866	0.173			
2.693	2.866	0.173			

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS	2448033	4482/25/EX/10/2025	26-09-2025
CALIBRATOR FLUKE 754			
FLUKE PRESURE MODULE 750PD6	6094437	02170/GQI-Sert/03/26	09-03-2026

Calibration Method

0003/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure Switch

This certificate comprises 2 pages
Date of issue, 10-06-2026

Customer Signature,

Ayrtton Humardani Putradhi

Approved Signatory,

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person